



NGUTC-2030-xx, NGUTC-2230-xx & NGUTC-VPAA-xx

xx is to be replaced by the appropriate program code number

RTD program code	Controlling sensor RTD1 (alarm in subscript)	Controlling sensor RTD2 (alarm in subscript)	High temperature sensor RTD3	Controlling sensor RTD3 (alarm in subscript)
FOR PLASTIC PIPE	01	3 °C (37.4 °F)	-	65 °C (149 °F)
	02	3 ₁ °C (37.4 _{33.8} °F)	-	65 °C (149 °F)
	03	5 °C (41 °F)	-	65 °C (149 °F)
	04	5 ₃ °C (41 _{37.4} °F)	-	65 °C (149 °F)
	05	10 °C (50 °F)	-	65 °C (149 °F)
	06	10 ₅ °C (50 ₄₁ °F)	-	65 °C (149 °F)
	07	15 °C (59 °F)	-	65 °C (149 °F)
	08	15 ₁₀ °C (59 ₅₀ °F)	-	65 °C (149 °F)
	09*	41 °C (105.8 °F)	-	85 °C (185 °F)
	11	3 °C (37.4 °F)	3 °C (37.4 °F)	65 °C (149 °F)
	12	3 ₁ °C (37.4 _{33.8} °F)	3 ₁ °C (37.4 _{33.8} °F)	65 °C (149 °F)
	13	5 °C (41 °F)	5 °C (41 °F)	65 °C (149 °F)
	14	5 ₃ °C (41 _{37.4} °F)	5 ₃ °C (41 _{37.4} °F)	65 °C (149 °F)
	15	10 °C (50 °F)	10 °C (50 °F)	65 °C (149 °F)
	16	10 ₅ °C (50 ₄₁ °F)	10 ₅ °C (50 ₄₁ °F)	65 °C (149 °F)
	17	15 °C (59 °F)	15 °C (59 °F)	65 °C (149 °F)
	18	15 ₁₀ °C (59 ₅₀ °F)	15 ₁₀ °C (59 ₅₀ °F)	65 °C (149 °F)
	19*	41 °C (105.8 °F)	41 °C (105.8 °F)	85 °C (185 °F)
	FOR METAL PIPE	21	3 °C (37.4 °F)	-
22		3 ₁ °C (37.4 _{33.8} °F)	-	-
23		5 °C (41 °F)	-	-
24		5 ₃ °C (41 _{37.4} °F)	-	-
25		10 °C (50 °F)	-	-
26		10 ₅ °C (50 ₄₁ °F)	-	-
27		15 °C (59 °F)	-	-
28		15 ₁₀ °C (59 ₅₀ °F)	-	-
31		3 °C (37.4 °F)	3 °C (37.4 °F)	-
32		3 ₁ °C (37.4 _{33.8} °F)	3 ₁ °C (37.4 _{33.8} °F)	-
33		5 °C (41 °F)	5 °C (41 °F)	-
34		5 ₃ °C (41 _{37.4} °F)	5 ₃ °C (41 _{37.4} °F)	-
35		10 °C (50 °F)	10 °C (50 °F)	-
36		10 ₅ °C (50 ₄₁ °F)	10 ₅ °C (50 ₄₁ °F)	-
37		15 °C (59 °F)	15 °C (59 °F)	-
38		15 ₁₀ °C (59 ₅₀ °F)	15 ₁₀ °C (59 ₅₀ °F)	-

*Usually for grease lines

Note: Other program codes available, contact GF Urecon for more details.

FOR METAL PIPE	41	3 °C (37.4 °F)	3 °C (37.4 °F)	-	3 °C (37.4 °F)
	42	3 ₁ °C (37.4 _{33.8} °F)	3 ₁ °C (37.4 _{33.8} °F)	-	3 ₁ °C (37.4 _{33.8} °F)
	43	5 °C (41 °F)	5 °C (41 °F)	-	5 °C (41 °F)
	44	5 ₃ °C (41 _{37.4} °F)	5 ₃ °C (41 _{37.4} °F)	-	5 ₃ °C (41 _{37.4} °F)
	45	10 °C (50 °F)	10 °C (50 °F)	-	10 °C (50 °F)
	46	10 ₅ °C (50 ₄₁ °F)	10 ₅ °C (50 ₄₁ °F)	-	10 ₅ °C (50 ₄₁ °F)
	47	15 °C (59 °F)	15 °C (59 °F)	-	15 °C (59 °F)
	48	15 ₁₀ °C (59 ₅₀ °F)	15 ₁₀ °C (59 ₅₀ °F)	-	15 ₁₀ °C (59 ₅₀ °F)